

Probeentnahmen aus den Pumpwerken

A. Bakteriologische Untersuchungen des kantonalen Laboratoriums

nn=nicht nachweisbar

B. Teilchemische Untersuchungen des kantonalen Laboratoriums

Art der Probe	Datum der Proben	Remeli	Löli 2	Löli 4	Löli 6	Netz
Wassertemp ° C	05.01.26	12.6	13.1	13.6	13.9	10.1
	09.02.26	12.8	13.4	13.6	14.0	10.3
	16.03.26	13.3	13.6	13.8	14.0	12.3
	27.04.26	13.5	13.6	13.8	13.9	14.7
	01.06.26	13.5	13.5	13.9	14.0	13.0
	29.06.26	13.4	13.6	13.8	14.1	19.6
	03.08.26	13.5	13.6	13.8	14.1	21.3
TOC mg c/l Toleranzwert 2.00	05.01.26			0.78		
	09.02.26	0.84	0.78			0.77
	16.03.26				0.70	
	27.04.26			0.75		
	01.06.26	0.84	0.76			
	29.06.26				0.72	
	03.08.26			0.77		
pHWert	05.01.26			7.39		
	09.02.26	7.44	7.43			7.56
	16.03.26				7.37	
	27.04.26			7.39		
	01.06.26	7.40	7.37			
	29.06.26				7.37	
	03.08.26			7.37		
Leitfähigkeit uS/cm	05.01.26			668		
	09.02.26	673	672			669
	16.03.26				675	
	27.04.26			670		
	01.06.26	669	667			
	29.06.26				676	
	03.08.26			689		
Trübung FNU Toleranzwert 1.0	05.01.26			0.060		
	09.02.26	0.070	0.150			0.180
	16.03.26				0.110	
	27.04.26			0.060		
	01.06.26	<0.05	0.050			
	29.06.26				0.060	
	03.08.26			0.090		
UVAbsorption l/m (SSK-254) /100cm	05.01.26			1.33		
	09.02.26	1.58	1.40			
	16.03.26				1.10	
	27.04.26			1.26		
	01.06.26	1.45	1.28			
	29.06.26				1.08	
	03.08.26			1.21		

Alkalität fr. H°	05.01.26			24.00		
	09.02.26	23.50	23.80			24.30
	16.03.26				24.50	
	27.04.26			23.50		
	01.06.26	22.60	23.20			
	29.06.26				24.70	
	03.08.26			23.40		
Calcium mg/l	05.01.26			112.00		
	09.02.26	111.00	111.00			112.00
	16.03.26				114.00	
	27.04.26			112.00		
	01.06.26	111.00	111.00			
	29.06.26				113.00	
	03.08.26			114.00		
Kalium mg/l	05.01.26			3.22		
	09.02.26	3.48	3.45			3.41
	16.03.26				3.16	
	27.04.26			3.38		
	01.06.26	3.52	3.47			
	29.06.26				3.29	
	03.08.26			3.51		
Magnesium mg/l	05.01.26			9.84		
	09.02.26	10.30	9.82			9.54
	16.03.26				9.01	
	27.04.26			9.47		
	01.06.26	10.20	9.96			
	29.06.26				8.97	
	03.08.26			9.65		
Natrium mg/l Toleranzwert 200	05.01.26			15.90		
	09.02.26	16.90	16.50			17.00
	16.03.26				17.00	
	27.04.26			16.60		
	01.06.26	16.80	16.80			
	29.06.26				17.10	
	03.08.26			17.30		
Summe Katic mmol/L	05.01.26			7.18		
	09.02.26	7.21	7.15			7.21
	16.03.26				7.25	
	27.04.26			7.18		
	01.06.26	7.20	7.18			
	29.06.26				7.21	
	03.08.26			7.31		
Chlorid mg/l	05.01.26			22.00		
	09.02.26	22.30	21.30			22.10
	16.03.26				23.50	
	27.04.26			23.30		
	01.06.26	23.30	22.90			
	29.06.26				23.10	
	03.08.26			25.50		

Fluorid mg/l Toleranzwert 1.5 mg/l	05.01.26			0.16		
	09.02.26	0.17	0.17			0.16
	16.03.26				0.17	
	27.04.26			0.17		
	01.06.26	0.17	0.17			
	29.06.26				0.15	
	03.08.26			0.17		
Nitrat mg/l Toleranzwert 40 mg/l	05.01.26			18.10		
	09.02.26	18.90	19.50			19.50
	16.03.26				19.20	
	27.04.26			18.70		
	01.06.26	17.00	17.20			
	29.06.26				18.10	
	03.08.26			18.40		
Sulfat mg/l	05.01.26			64.50		
	09.02.26	72.40	67.30			62.70
	16.03.26				55.60	
	27.04.26			60.60		
	01.06.26	75.90	67.90			
	29.06.26				54.50	
	03.08.26			65.50		
Summe Anio mmol/L	05.01.26			7.06		
	09.02.26	7.16	7.09			7.12
	16.03.26				7.04	
	27.04.26			6.93		
	01.06.26	7.03	6.98			
	29.06.26				7.02	
	03.08.26			7.07		
Bleibende H_z fr. H°	05.01.26			8.09		
	09.02.26	8.43	7.92			7.59
	16.03.26				7.59	
	27.04.26			8.35		
	01.06.26	9.33	8.64			
	29.06.26				7.24	
	03.08.26			8.94		
Gesamthärte fr. H°	05.01.26			32.00		
	09.02.26	31.90	31.70			31.90
	16.03.26				32.10	
	27.04.26			31.90		
	01.06.26	31.90	31.80			
	29.06.26				31.90	
	03.08.26			32.30		
Fehler Ionen %	05.01.26			1.80		
	09.02.26	0.80	0.90			1.30
	16.03.26				2.80	
	27.04.26			3.60		
	01.06.26	2.40	2.80			
	29.06.26				2.60	
	03.08.26			3.30		